

System Studies Incorporated



2-1340 East Cliff Drive
 Santa Cruz, CA 95062
 (831) 475-5777
 (800) 247-8255
 (831) 475-9207 FAX
 www.airtalk.com

Flow Transducer Conversion Chart (SCFH/mA)				
Flow in SCFH				Current in mA
9.5	19.0	47.5	95.0	
0.0	0.0	0.0	0.0	3.6 - 4.03
1.0	2.0	5.0	10.0	4.04
2.0	4.0	10.0	20.0	4.18
3.0	6.0	15.0	30.0	4.40
4.0	8.0	20.0	40.0	4.71
5.0	10.0	25.0	50.0	5.11
6.0	12.0	30.0	60.0	5.57
7.0	14.0	35.0	70.0	6.17
8.0	16.0	40.0	80.0	6.84
9.0	18.0	45.0	90.0	7.59
10.0	20.0	50.0	100.0	8.43
11.0	22.0	55.0	110.0	9.36
12.0	24.0	60.0	120.0	10.38
13.0	26.0	65.0	130.0	11.49
14.0	28.0	70.0	140.0	12.69
15.0	30.0	75.0	150.0	13.97
16.0	32.0	80.0	160.0	15.35
17.0	34.0	85.0	170.0	16.81
18.0	36.0	90.0	180.0	18.36
19.0	38.0	95.0	190.0	19.99